



# Town of Friday Harbor Water, Wastewater, and Solid Waste Utilities Summary Reports

[www.fridayharbor.org](http://www.fridayharbor.org)

**Period ending: Dec 2020**

Data provided by  
Wayne Haefele, PE, Public Works Director  
Water Utility, Mike Deegan, Water System Mgr.  
Frank Byrne, Water Treatment Plant Operator  
Wastewater Utility, Don Reitan, Leadman  
Solid Waste Utility, Dave Smith, Leadman

Analysis & Reports prepared by  
Mike Greene, System Administrator

---

**Water - use MTD**sourceDate  
/  
12 / 2020

Spe=Special, Sfr=Single Family Residential, P.A= Public Authority, Mfr=Multi-family, Ind=Industrial, Com=Commerc

---

<b>Water Class</b>	<b>Accounts</b>	<b>Gallons</b>
Spe	2	28,300
Sfr	1000	2,518,610
PA	79	424,420
Mfr	131	1,717,840
Ind	14	89,190
Com	222	993,490
<b>TOTAL</b>	<b>1,448</b>	<b>5,771,850</b>

---

**Water use MTD - accounts with sewer**sourceDate  
/  
12 / 2020

---

<b>Sewer Class</b>	<b>Accounts</b>	<b>Gallons</b>
<b>Location: IN</b>		
Mfr In/low Strength	70	762,010
Com In/lo Strength	163	539,400
Dot In/lo Strength	3	19,780
Ind In/hi Strength	1	26,750
Ind In/lo Strength	10	53,290
Lmf In/lo Strength	1	4,230
Com In/hi Strength	45	376,590
Mfr In/lo Strength	51	471,430
Mhp In/lo Strength	2	333,700
PA In/hi Strength	3	30,290
PA In/lo Strength	43	154,640
Sfr IN Town	624	1,660,770
Low Rate / IN Town	6	7,740
	<hr/> 1022	<hr/> 4,440,620
<b>Location: Out</b>		
UW Out/hi Strength	1	134,900
Mfr Out/lo Strength	1	4,740
Sfr Out of Town	4	8,040
	<hr/> 6	<hr/> 147,680

---

---

<b>Sewer Class</b>	<b>Accounts</b>	<b>Gallons</b>
<b>TOTAL</b>	<b>1028</b>	<b>4,588,300</b>

---

---

**Water - use MTD by Location**sourceDate  
/  
12 / 2020

Spe=Special, Sfr=Single Family Residential, P.A= Public Authority, Mfr=Multi-family, Ind=Industrial, Com=Commerc

---

<b>Water Class</b>	<b>Accounts</b>	<b>Gallons</b>
<b>Location: IN</b>		
Spe	2	28,300
Sfr	646	1,690,040
PA	70	266,900
Mfr	126	1,611,800
Ind	13	87,050
Com	219	935,450
	<b>1,076</b>	<b>4,619,540</b>
<b>Location: Out</b>		
Sfr	354	828,570
PA	9	157,520
Mfr	5	106,040
Ind	1	2,140
Com	3	58,040
	<b>372</b>	<b>1,152,310</b>
<b>TOTAL</b>	<b>1,448</b>	<b>5,771,850</b>

---

**Refuse - pickups by Class**

sourceDate  
/  
12 / 2020

Location	Class	Pickups
IN	Sfr	1,723.0
	RefuseOnly	200.5
	PA	114.0
	Mfr	481.0
	Ind	16.0
	Com	1,304.5
		<hr/> 3,839.0
Out	Mfr	8.0
		<hr/> 8.0
<b>TOTAL</b>		<b>3,847.0</b>

---

**Refuse - active accounts**sourceDate  
/  
12 / 2020

---

Location	Refuse Type	Accounts
IN		
	Small Dumpster	45
	PA	39
	Medium Dumpste	49
	Large Dumpster	69
	Compactors	4
	Cans Low Rate	6
	Cans	855
		<hr/> 1,067
Out		
	Large Dumpster	1
		<hr/> 1
	<b>TOTAL</b>	<b>1,068</b>

**Recycle - pickups by Class**

sourceDate  
/  
12 / 2020


Location	Class	Pickups
IN	Sfr	746
	RefuseOnly	29
	PA	0
	Mfr	68
	Ind	2
	Com	4
		<b>849</b>
Out	Mfr	0
		<b>0</b>
<b>TOTAL</b>		<b>849</b>



## Refuse Pickups - 2020 YTD

Account Type	SFR	Refuse Only	P.A	MFR	IND	COM	Other	Total
Jan	1,273.0	188.0	143.5	410.0	15.5	1,578.5	3.5	3,612.0
Feb	1,593.0	239.5	166.0	473.0	21.5	1,943.0	3.0	4,439.0
Mar	1,482.0	223.5	153.0	426.5	19.0	1,883.5	3.5	4,191.0
Apr	1,785.0	164.5	59.0	501.5	16.5	1,221.5	8.0	3,756.0
May	2,175.0	181.5	64.5	550.0	18.0	1,321.5	8.5	4,319.0
Jun	2,084.0	197.0	73.5	529.0	20.0	1,776.5	11.5	4,691.5
Jul	2,099.0	240.5	69.5	566.0	14.5	2,171.5	11.5	5,172.5
Aug	2,374.0	276.5	74.0	610.5	19.5	2,344.0	14.0	5,712.5
Sep	2,019.0	260.5	95.5	537.0	26.5	1,995.5	11.0	4,945.0
Oct	2,077.0	268.0	106.0	548.5	20.0	2,019.0	10.0	5,048.5
Nov	2,319.0	239.5	119.5	590.0	17.5	1,381.0	9.0	4,675.5
Dec	1,723.0	200.5	114.0	481.0	16.0	1,304.5	8.0	3,847.0
YTD	23,003.0	2,679.5	1,238.0	6,223.0	224.5	20,940.0	101.5	54,409.5

# Refuse Pickups by Month - 2020



**Finish Water Flow to Town**  
source: Water Treatment Facility Monthly Report

Revised reporting period: per K. Anderson 03/06/17  
to reflect meter reading dates (?).  
Start/End dates may change monthly.

29 :count of days in reporting period.

	November 16, 2020		December 14, 2020
day	flow (total flow)	day	flow (total flow)
13		1	272
14		2	295
15		3	192
16	244	4	274
17	246	5	257
18	229	6	224
19	227	7	230
20	202	8	227
21	261	9	214
22	195	10	131
23	235	11	176
24	211	12	261
25	271	13	206
26	270	14	237
27	266	15	
28	178	16	
29	212		
30	311		
31			
days	3558	days	3196
	TOTAL DAYS	29	
	TOTAL FLOW		6754
			1,000's gallons

TOWN OF FRIDAY HARBOR

Flow to Town (Gross Water Production) 2020

Revised reporting period: per K. Anderson 03/06/17  
to reflect meter reading dates (?).

Reporting (meter reading) period			days in period	Gross flow to Town	Flow to Town (millions)
<i>from WTP Chem. Wts. &amp; Finish Flow to Town Report</i>	<i>to</i>				
16-Dec	<i>to</i>	12-Jan	28	6,771,000	6,771
13-Jan		13-Feb	32	7,991,000	7,991
14-Feb		15-Mar	31	7,169,000	7,169
16-Mar		14-Apr	30	6,984,000	6,984
15-Apr		14-May	30	7,971,000	7,971
15-May		14-Jun	31	9,137,000	9,137
15-Jun		14-Jul	30	10,903,000	10,903
15-Jul		16-Aug	33	14,737,000	14,737
17-Aug		14-Sep	29	11,463,000	11,463
15-Sep		14-Oct	30	8,823,000	8,823
15-Oct		15-Nov	32	7,733,000	7,733
16-Nov		14-Dec	29	6,754,000	6,754
			365	106,436,000	106436.0

TOWN OF FRIDAY HARBOR

**WATER CONSUMPTION (Use) BY CUSTOMER CLASS**

source: utilTry08 & 13.mdb

2018

CLASS:	COM	IND	MFR	P.A	SFR	Special	other uses	TOTAL	% of Use	Avg. Daily Use
JAN	1,250,270	69,660	1,349,580	607,870	2,203,780	17,222	694,751	6,193,133	5.7%	199,778
FEB	1,500,170	71,310	1,618,790	688,000	2,665,520	41,199	828,250	7,413,239	6.8%	255,629
MAR	1,241,570	75,040	1,397,840	559,420	2,041,730	17,517	732,194	6,065,311	5.6%	195,655
APR	1,684,280	82,120	1,658,130	1,095,020	2,433,950	8,070	890,947	7,852,517	7.2%	261,751
MAY	1,870,990	106,370	1,714,050	1,072,220	2,988,690	53,173	854,665	8,660,158	8.0%	279,360
JUN	2,517,020	203,770	2,147,470	1,893,510	4,289,890	109,235	867,127	12,028,022	11.1%	400,934
JUL	2,623,370	261,470	2,060,480	2,149,290	4,135,760	117,755	773,844	12,121,969	11.1%	391,031
AUG	3,160,640	289,630	2,187,810	2,573,210	4,922,790	64,549	667,359	13,865,988	12.8%	447,290
SEP	2,774,070	235,700	2,160,460	2,155,220	4,169,510	127,141	548,063	12,170,164	11.2%	405,672
OCT	1,700,260	99,490	1,833,510	1,308,870	2,663,670	40,958	768,703	8,415,461	7.7%	271,466
NOV	1,516,500	104,840	1,693,090	989,960	2,537,410	33,727	405,666	7,281,193	6.7%	242,706
DEC	1,308,380	93,000	1,584,960	849,590	2,356,950	13,677	449,197	6,655,754	6.1%	214,702
<b>TOTAL</b>	<b>23,147,520</b>	<b>1,692,400</b>	<b>21,406,170</b>	<b>15,942,180</b>	<b>37,409,650</b>	<b>644,223</b>	<b>8,480,764</b>	<b>108,722,907</b>	<b>100.0%</b>	<b>297,057</b>
<b>AVERAGE</b>	<b>1,928,960</b>	<b>141,033</b>	<b>1,783,848</b>	<b>1,328,515</b>	<b>3,117,471</b>	<b>53,685</b>	<b>706,730</b>	<b>108,722,907</b>	<b>USE for Year</b>	<b>-7,064,093</b>

% of USE	21.3%	1.6%	19.7%	14.7%	34.4%	0.6%	7.8%	100.0%	100.0%	115,787,000
% of FLOW	20.0%	1.5%	18.5%	13.8%	32.3%	0.6%	7.3%	93.9%	93.9%	Loss as % of Flow

2020

CLASS:	COM	IND	MFR	P.A	SFR	Special	other uses	TOTAL	% of Use	Avg. Daily Use
JAN	1,245,000	106,800	1,477,460	778,750	2,353,930	8,953	519,909	6,490,802	6.4%	209,381
FEB	1,472,570	103,550	1,708,290	877,370	2,579,290	31,010	586,762	7,358,842	7.2%	253,753
MAR	1,269,760	79,450	1,581,430	597,760	2,269,100	15,009	668,075	6,480,584	6.4%	209,051
APR	855,070	67,640	1,845,470	421,860	2,823,760	41,241	621,772	6,676,813	6.6%	222,560
MAY	979,450	83,580	1,960,930	673,160	3,435,470	102,507	630,453	7,865,550	7.7%	253,727
JUN	1,163,080	85,270	2,111,320	827,450	3,654,370	42,123	699,038	8,582,651	8.4%	286,088
JUL	1,887,081	227,720	2,157,360	1,425,030	4,208,750	64,034	730,079	10,700,054	10.5%	345,163
AUG	2,827,729	284,390	2,761,380	2,072,320	5,553,590	139,076	800,183	14,438,668	14.2%	465,763
SEP	2,207,410	222,810	2,194,420	1,543,250	4,211,890	112,212	579,688	11,071,680	10.9%	369,056
OCT	1,679,380	128,740	2,014,950	1,065,460	2,981,580	41,258	675,971	8,587,339	8.4%	277,011
NOV	1,265,230	97,420	1,931,840	618,010	2,785,370	30,930	557,304	7,286,104	7.1%	242,870
DEC	993,490	89,190	1,717,840	424,420	2,518,610	28,300	604,796	6,376,646	6.3%	205,698
<b>TOTAL</b>	<b>17,845,250</b>	<b>1,576,560</b>	<b>23,462,690</b>	<b>11,324,840</b>	<b>39,375,710</b>	<b>656,653</b>	<b>7,674,030</b>	<b>101,915,733</b>	<b>100.0%</b>	<b>278,458</b>
<b>AVERAGE</b>	<b>1,487,104</b>	<b>131,380</b>	<b>1,955,224</b>	<b>943,737</b>	<b>3,281,309</b>	<b>54,721</b>	<b>639,503</b>	<b>101,915,733</b>	<b>USE for Year</b>	<b>-4,520,267</b>

% of USE	17.5%	1.5%	23.0%	11.1%	38.6%	0.6%	7.5%	100.0%	100.0%	106,436,000
% of FLOW	16.8%	1.5%	22.0%	10.6%	37.0%	0.6%	7.2%	95.8%	95.8%	Loss as % of Flow

TOWN OF FRIDAY HARBOR

Net Water Production - 2020

amounts in gallons

	Jan	Feb	Mar	Apr	May	Jun
Gross Production for billing period from WTP Chemical Weights & Finish Flow to Town Report	6,771,000	7,991,000	7,169,000	6,984,000	7,971,000	9,137,000
3% meter loss	179,127	203,162	174,375	181,651	217,053	236,508
Flushing	129,200	155,800	282,600	126,975	212,000	210,350
SJC#3 FD use	5,000	5,000	5,000	5,000	5,000	5,000
Leaks	206,582	222,800	206,100	308,146	196,400	247,180
notes						
other non-metered use						
notes						
Additional water in storage						
notes						
Total other uses	-519,909	-586,762	-668,075	-621,772	-630,453	-699,038
<b>Net production</b>	<b>6,251,091</b>	<b>7,404,238</b>	<b>6,500,925</b>	<b>6,362,228</b>	<b>7,340,547</b>	<b>8,437,962</b>

	Jul	Aug	Sep	Oct	Nov	Dec
Gross Production for billing period from WTP Chemical Weights & Finish Flow to Town Report	10,903,000	14,737,000	11,463,000	8,823,000	7,733,000	6,754,000
3% meter loss	299,099	409,155	314,760	237,341	201,864	173,156
Flushing	230,550	159,200	66,000	84,300	127,000	199,250
SJC#3 FD use	5,000	5,000	5,000	5,000	5,000	5,000
Leaks	195,430	226,828	193,928	349,330	223,440	227,390
notes						
other non-metered use						
notes						
Total other uses	-730,079	-800,783	-579,688	-675,971	-557,304	-604,796
<b>Net production</b>	<b>10,172,921</b>	<b>13,936,817</b>	<b>10,883,312</b>	<b>8,147,029</b>	<b>7,175,696</b>	<b>6,149,205</b>

TOWN OF FRIDAY HARBOR

# Water Consumption & Production

Revised meter loss reporting begin 07/09 (per Robert Krebs, Evergreen Rural Water Assoc.)

Period	USE (consumption)	Cumulative Use YTD	Flow (production)	Unaccounted over / (under)	Cumulative Flow YTD	Average Daily Flow					
<b>2018</b>											
<i>gallons</i>	Jan-18	6,473,834	7,347,000	-873,166		237,000					
	Feb-18	6,318,823	12,792,658	-735,177	14,401,000	251,929					
	Mar-18	5,860,732	18,653,389	-705,268	20,967,000	211,806					
	Apr-18	7,416,815	26,070,204	-839,185	29,223,000	275,200					
	May-18	7,687,108	33,757,312	-244,892	37,155,000	255,871					
	Jun-18	11,419,190	45,176,502	-519,810	49,094,000	397,967					
	Jul-18	13,151,864	58,328,366	-1,029,136	63,275,000	457,452	YTD				
	Aug-18	14,508,241	72,836,607	-855,759	78,639,000	495,613	Unaccounted				
	Sep-18	12,454,526	85,291,133	-1,314,474	92,408,000	458,967	as % of Flow				
Average	Oct-18	8,624,468	93,915,601	-551,532	101,584,000	296,000	5.10%				
Monthly Use	Nov-18	7,401,706	101,317,307	-920,294	109,906,000	277,400					
9,031,729	Dec-18	7,063,439	108,380,746	-1,161,561	118,131,000	265,323	-5,914,508				
<b>YEAR TOTAL:</b>	12	108,899,956	Cumulative Metered/Other Use YTD	118,131,000	-9,750,254	Cumulative Unaccounted 3% meter loss	323,377 2,915,731				
<b>2019</b>											
<i>gallons</i>	Jan-19	6,193,133	6,982,000	-788,867		225,226					
	Feb-19	7,413,239	13,606,372	-451,761	14,847,000	280,893					
	Mar-19	6,065,311	19,671,683	-1,402,689	22,315,000	240,903					
	Apr-19	7,852,517	27,524,200	-751,483	30,919,000	286,800					
	May-19	8,660,158	36,184,358	-861,842	40,441,000	307,161					
	Jun-19	12,028,022	48,212,379	-466,978	52,936,000	416,500					
	Jul-19	12,121,969	60,334,348	-37,031	65,095,000	392,226	YTD				
	Aug-19	13,865,988	74,200,336	-111,012	79,072,000	450,871	Unaccounted				
	Sep-19	12,170,164	86,370,500	-552,836	91,795,000	424,100	as % of Flow				
Average	Oct-19	8,415,461	94,785,961	-452,539	100,663,000	286,065	8.25%				
Monthly Use	Nov-19	7,281,193	102,067,154	-426,807	108,371,000	256,933					
9,060,242	Dec-19	6,655,754	108,722,907	-760,246	115,787,000	239,226	-9,750,254				
<b>YEAR TOTAL:</b>	12	108,722,907	Cumulative Metered/Other Use YTD	115,787,000	-7,064,093	Cumulative Unaccounted 3% meter loss	317,242 2,989,222				
<b>2020</b>											
<i>gallons</i>	Jan-20	6,490,802	6,771,000	-280,198		218,419					
	Feb-20	7,358,842	13,849,644	-632,158	14,762,000	285,393					
	Mar-20	6,480,584	20,330,228	-688,416	21,931,000	231,258					
	Apr-20	6,676,813	27,007,042	-307,187	28,915,000	232,800					
	May-20	7,865,550	34,872,592	-105,450	36,886,000	257,129					
	Jun-20	8,582,651	43,455,243	-554,349	46,023,000	304,567					
	Jul-20	10,700,054	54,155,297	-202,946	56,926,000	351,710	YTD				
	Aug-20	14,438,668	68,593,965	-298,332	71,663,000	475,387	Unaccounted				
	Sep-20	11,071,680	79,665,645	-391,320	83,126,000	382,100	as % of Flow				
Average	Oct-20	8,587,339	88,252,984	-235,661	91,949,000	284,613	4.25%				
Monthly Use	Nov-20	7,286,104	95,539,088	-446,896	99,682,000	257,767					
8,492,978	Dec-20	6,376,646	101,915,733	-377,355	106,436,000	217,871	-4,520,267				
<b>YEAR TOTAL:</b>	12	101,915,733	Cumulative Metered/Other Use YTD	106,436,000	-4,520,267	Cumulative Unaccounted 3% meter loss	291,584 2,827,251				
<b>3 YEAR AVERAGES:</b>	Use	5,855,991	:gal/month	Flow	9,454,278	:gal/month	Daily Flow	202,942	3 Year Loss	as % of Flow	<b>5.93%</b>

source: Monthly Water Treatment Plant Report & utility.mdb's

3 yr cumulative flow 340,354,000  
3 yr unaccounted -20,185,028

## Utilization of Sustainable Annual Water System Capacity

Period start: Jan-20

Period end: Dec-20

Sustainable Annual Yield (TFH  
Comprehensive Water System Plan  
Update, June, 2013, page 3-6)

205 million gallons

Annual use - 12 month period  
percent of Sustainable Annual Yield

106.4 million gallons  
51.9%

Exceeds Sustainable Yield?

**No**



**Trout Lake Reservoir Level**

Months with positive levels may reflect that a removable 7.25 inch riser has been added to the top of the original spillway.

end of	Inches above/(below) original spillway	end of	Inches above/(below) original spillway	end of	Inches above/(below) original spillway
Jan-12	-1.75	Jan-15	0.00	Jan-18	0.00
Feb-12	0.00	Feb-15	0.00	Feb-18	0.00
Mar-12	0.00	Mar-15	0.00	Mar-18	8.75
Apr-12	8.00	Apr-15	6.50	Apr-18	8.25
May-12	0.00	May-15	0.00	May-18	1.50
Jun-12	7.00	Jun-15	-13.00	Jun-18	-10.50
Jul-12	-19.00	Jul-15	-29.50	Jul-18	-29.50
Aug-12	-32.75	Aug-15	-42.25	Aug-18	-42.00
Sep-12	-45.00	Sep-15	-49.50	Sep-18	-50.00
Oct-12	-48.00	Oct-15	-54.50	Oct-18	-54.50
Nov-12	-24.25	Nov-15	-17.25	Nov-18	-55.50
Dec-12	0.00	Dec-15	0.00	Dec-18	-26.00
Jan-13	0.00	Jan-16	0.00	Jan-19	0.00
Feb-13	0.00	Feb-16	0.00	Feb-19	0.00
Mar-13	0.00	Mar-16	0.00	Mar-19	2.75
Apr-13	8.50	Apr-16	6.00	Apr-19	2.75
May-13	3.75	May-16	-2.50	May-19	-0.75
Jun-13	-3.75	Jun-16	-11.00	Jun-19	-2.00
Jul-13	-21.00	Jul-16	-21.00	Jul-19	-16.00
Aug-13	-34.25	Aug-16	-36.50	Aug-19	-26.25
Sep-13	-39.25	Sep-16	-49.50	Sep-19	-40.00
Oct-13	-43.50	Oct-16	-51.00	Oct-19	-46.25
Nov-13	-44.75	Nov-16	-45.50	Nov-19	-49.75
Dec-13	-26.00	Dec-16	-10.35	Dec-19	-49.50
Jan-14	0.00	Jan-17	0.00	Jan-20	-11.00
Feb-14	0.00	Feb-17	0.00	Feb-20	0.00
Mar-14	0.00	Mar-17	2.75	Mar-20	0.00
Apr-14	8.25	Apr-17	9.00	Apr-20	4.00
May-14	5.00	May-17	4.75	May-20	0.00
Jun-14	7.00	Jun-17	-4.00	Jun-20	-0.75
Jul-14	-20.50	Jul-17	-19.00	Jul-20	-8.50
Aug-14	-30.25	Aug-17	-32.00	Aug-20	-22.50
Sep-14	-42.75	Sep-17	-43.00	Sep-20	-34.00
Oct-14	-45.25	Oct-17	-50.50	Oct-20	-42.50
Nov-14	-46.50	Nov-17	-48.00	Nov-20	-45.25
Dec-14	0.00	Dec-17	-11.50	Dec-20	-28.25

# Rainfall - Trout Lake Water Treatment Facility

source: Water Treatment Plant Weather Reports

*all figures in inches*

	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	average (2005-14)
JAN	5.49	6.87	6.51	2.34	3.82	4.73	5.90	3.46	4.14	2.86	4.61
FEB	1.01	1.61	2.83	1.78	1.50	1.24	2.74	3.38	1.32	4.22	2.16
MAR	2.33	0.91	3.70	1.99	2.05	3.30	3.37	3.09	3.63	3.88	2.83
APR	1.37	2.23	1.49	1.32	2.07	1.47	2.96	1.91	2.70	1.94	1.95
MAY	1.08	1.24	0.78	1.26	1.69	2.09	3.07	1.09	2.20	1.05	1.56
JUN	1.63	0.56	1.03	1.16	0.35	1.10	0.68	2.60	0.83	0.52	1.05
JUL	0.70	0.26	1.56	0.21	0.45	0.11	0.84	1.04	0.00	0.36	0.55
AUG	1.60	0.03	0.64	1.88	0.81	0.72	0.29	0.00	0.95	0.49	0.74
SEP	0.94	1.15	0.54	0.84	1.58	4.35	0.72	0.12	5.08	1.34	1.67
OCT	3.50	1.89	2.12	1.83	5.24	1.38	2.29	6.40	1.42	4.00	3.01
NOV	4.28	10.43	2.32	5.15	6.76	2.94	4.50	3.32	2.49	4.00	4.62
DEC	2.89	3.74	4.59	3.70	1.80	6.55	1.88	4.79	2.28	3.37	3.56
<b>Total</b>	<b>26.82</b>	<b>30.92</b>	<b>28.11</b>	<b>23.46</b>	<b>28.12</b>	<b>29.98</b>	<b>29.24</b>	<b>31.20</b>	<b>27.04</b>	<b>28.03</b>	<b>28.29</b>

Cumulative thru

<b>DEC</b>	<b>26.82</b>	<b>30.92</b>	<b>28.11</b>	<b>23.46</b>	<b>28.12</b>	<b>29.98</b>	<b>29.24</b>	<b>31.20</b>	<b>27.04</b>	<b>28.03</b>
------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------

*all figures in inches*

	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
JAN	3.97	2.17	1.60	5.10	3.87	7.32				
FEB	2.95	4.83	2.99	3.80	1.76	5.34				
MAR	3.62	2.88	3.27	1.48	0.87	1.25				
APR	0.51	0.75	2.20	3.10	1.61	1.38				
MAY	0.30	0.48	1.61	0.07	1.29	1.49				
JUN	0.14	1.22	0.75	0.72	0.61	1.25				
JUL	0.36	0.32	0.15	0.18	0.75	0.86				
AUG	0.94	0.11	0.11	0.01	0.84	0.68				
SEP	1.28	1.40	0.71	1.27	2.74	2.34				
OCT	3.53	4.80	4.28	2.23	3.33	3.39				
NOV	6.19	3.47	4.32	4.32	2.1	4.68				
DEC	5.26	4.02	3.83	4.26	3.63	6.81				
<b>Total</b>	<b>29.05</b>	<b>26.45</b>	<b>25.82</b>	<b>26.54</b>	<b>23.40</b>	<b>36.79</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>

Cumulative thru

<b>DEC</b>	<b>29.05</b>	<b>26.45</b>	<b>25.82</b>	<b>26.54</b>	<b>23.40</b>	<b>36.79</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>
------------	--------------	--------------	--------------	--------------	--------------	--------------	-------------	-------------	-------------	-------------

# Prevention of Wastewater Facility Overloading

Period start: Dec-19  
 Period end: Nov-20

INFLUENT BOD LOADING (pounds per day)	AVG. EFFLUENT FLOW (millions of gallons per day)	SUSPENDED SOLIDS LOADING (pounds per day)
Design Criteria (06/06 NPDES Permit #WA-002358-2, pg 12, paragraph S4.A) max.month 1,600	Design Criteria (06/06 NPDES Permit #WA-002358-2, pg 12, paragraph S4.A) max.month 0.69000	Design Criteria (06/06 NPDES Permit #WA-002358-2, pg 12, paragraph S4.A) max.month 1,110
85% Capacity Planning Threshold (06/06 NPDES Permit #WA-002358-2, pg 12, paragraph S4.B.1) 1,360	85% Capacity Planning Threshold (06/06 NPDES Permit #WA-002358-2, pg 12, paragraph S4.B.1) 0.58650	85% Capacity Planning Threshold (06/06 NPDES Permit #WA-002358-2, pg 12, paragraph S4.B.1) 944
Month with highest average loading in period Jan-19	Month with highest average flow in period Jan-19	Month with highest average loading in period Jan-19
Highest average monthly loading in period (pounds per day) 559	Highest average monthly flow in period (millions of gallons per day) 0.4088414	Highest average monthly loading in period (pounds per day) 488
% of Design Criteria <b>35%</b>	% of Design Criteria <b>59%</b>	% of Design Criteria <b>44%</b>
exceeds Design Criteria? <b>No</b>	exceeds Design Criteria? <b>No</b>	exceeds Design Criteria? <b>No</b>
Previous month's loading 509	Previous month's flow 0.2541	Previous month's loading 319
Following month's loading 524	Following month's flow 0.2799	Following month's loading 245
exceeds Planning Threshold for 3 consecutive months? <b>No</b>	exceeds Planning Threshold for 3 consecutive months? <b>No</b>	exceeds Planning Threshold for 3 consecutive months? <b>No</b>