



NOTE: SPACING FOR PIPE ANCHORS TO BE ● MAX. 20' INTERVALS.

PIPE ANCHOR DETAIL
N.T.S.

TOWN OF FRIDAY HARBOR			
PIPE ANCHOR DETAIL			
APPROVED: <i>C. King</i> 1/16/97 TOWN ADMINISTRATOR			DWG. NO. 5-12
DATE: 1/16/97	DRWN: L.T.	CHKD: T.N.	SCALE: NO SCALE